



LEON VALLEY PUBLIC LIBRARY CHILDREN'S WING

ADDENDUM #1

CHANGES

1. Storefront wind resistance requirements should read 20 to 22 PSF in lieu of 70 PSF.
2. The toilet room, located in the existing Library that has been shown to be removed and remodeled, has been deleted from the scope of work and all references to plans, details, etc. are to be deleted from the Base Bid.
3. The electronic version of your bid is no longer mandatory.

OTHER INFORMATION

1. Once the bid is awarded by City Council, construction may begin immediately.
2. Tie into existing fire alarm and security will be by owner and not a part of this bid.
3. The Library will remain open for business throughout the majority of construction; and will only close during the final phase of construction, as negotiated.

Bidders are required to acknowledge this addendum on the Bid Form.

Rhonda Hewitt
Purchasing Agent